

JUNE 1, 2020

ADDENDUM NO. 3  
CITY OF SANGER

WELL NO. 16 DRILLING AND DEVELOPMENT


NOTICE

Notice is hereby given that the plans and specifications for this project have been revised as prescribed by this Addendum. It is mandatory that all bidders comply with the changes detailed herein. This Addendum shall be signed by the Bidder and attached to the inside of the Contract Documents. All changes, omissions, additions and alterations in, on and to the Contract Documents and Specification will apply to proposals made for the execution of the various parts of the work affected thereby. Careful note of this Addendum shall be taken by all parties of interest so that the proper allowance may be made in all computations, estimates and contracts, and all trades affected shall be fully advised in the performance of the work which will be required by them. In cases of conflict between the Plans, Specifications and this Addendum, this Addendum shall govern.

Bidders' Acknowledgment

Joshua D. Rogers

\_\_\_\_\_  
Bidder's Authorized Representative

  
\_\_\_\_\_  
Sanger City Engineer

ADDENDUM NO. 3  
CITY OF SANGER  
PUBLIC WORKS DEPARTMENT

WELL NO. 16 DRILLING AND DEVELOPMENT

1. Clarification, Bid Proposal

Pages 7-16 of the Specifications constitute the bid proposal. (See attached Bid Proposal) They must be submitted by all Bidders in accordance with the Notice Inviting Bids.

2. Specifications, Section 38.25, Hours of Work

Delete the first paragraph and replace with the following:

“Well drilling operations shall normally be between the hours of 7:00 a.m. and 6:00 p.m. Monday through Friday only; however, the decision whether drilling will be continuous or interrupted will be made by the Contractor and Geologist upon their assessment of the strata being drilled. If night drilling is approved, the contractor shall notify the Engineer, Sanger Police Department and nearby residents of his/her night drilling activities. Said notification shall be provided as soon as it becomes known that the drilling period will be extended into the night, and for what anticipated duration. All efforts shall be taken by the Contractor to limit noise and dispersion of construction lighting to the adjoining areas.”