



ELEVATION VIEW

WALL SECTION

GENERAL NOTES

1. ALL APPLICABLE SECTIONS OF THE CALIFORNIA BUILDING CODE SHALL BE COMPLIED WITH
2. WALL THICKNESS SHALL BE EITHER 6" OR 8", AS SPECIFIED
3. BLOCK WALLS MAY BE OF HOLLOW MASONRY CONSTRUCTION GROUTED IN CELLS CONTAINING VERTICAL AND HORIZONTAL REINFORCEMENT.
4. MORTAR SHALL CONSIST OF PORTLAND CEMENT AND SAND, MEETING TYPE "S" REQUIREMENTS

CONCRETE BLOCK FENCE

REVISIONS  
01/17/2008

CITY OF SANGER  
07-20-1995

STD.  
NO.  
M-3

PAGE 4