



City of Sanger, California
Community Development Department
Building and Safety Division
1700 7th Street, Sanger, CA 93657
Phone: (559) 876-6300 Ext. 1570
www.ci.sanger.ca.us

Minimum Requirements for Temp Power Approval

- 1) Minimum size of main service shall be no less than 100 amps
 - a. Service entrance conductors shall be sized appropriately for main service amperage according to 2019 CEC
- 2) Service entrance mast with approved weather head mounted/secured/strapped as required (if applicable)
- 3) Main service panel grounding connection (either/or)
 - a. Two 8' ground rods spaced 6' apart with continuous #8 AWG armored grounding conductor
 - b. A ground ring that is no smaller than #2 AWG bare copper conductor that is in direct contact with the earth for at least 20'
 - c. When possible, concrete encased 20' min. long #4 rebar (Ufer Ground)
- 4) When applicable, water piping bonded with listed clamp or other listed means
- 5) All overcurrent protection devices (breakers) properly identified & labeled
- 6) All 120/240-volt circuits shall be GFCI protected and in an approved weather tight enclosure

NOTE: It is the contractor/ owner's responsibility to contact PG&E to arrange for service connection following city inspection

